

**Public Notice
City of Gordon**

SURFACE WATER TREATMENT TECHNIQUE

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches. You do not need to use an alternative water supply.

The CITY OF GORDON, PWS ID TX1820007, failed to meet the minimum treatment technique requirements for the month of DECEMBER 2022 . Specifically, our water system had

Low Disinfection Contact Time (CT) for more than four consecutive hours.

"The City of Gordon has taken the following corrective actions to prevent a recurrence of the violations:

The City of Gordon has consulted with TCEQ and our Engineers to make adjustments in the treatment process.

If you have questions regarding this matter, you may contact Jonathan Imes at 254-693-5676

Teresa Johnson
City Administrator

Posted /Delivered on: 1/10/2023
